



Date: 4/5/2017 **Author:** Branden Leightizer **Project:** Halifax Hospice
Contractor: Lindsay's Construction **Plan:** Traffic Plan

Comments:

Setup shall follow Guide C22 in the NSTWTCM
 Minimum of 5.5m of travel lane shall be maintained at all times.
 Pedestrians shall be provided a temporary sidewalk **See Encroachment Plan

